

<u>T OF NATIONAL CAPITAL TERRITORY OF DELHI</u> **DELHI FIRE SERVICE, NEW DELHI-110001**

Dated: 20/08 /2024

The Principal, Nigam Pratibha Vidyalaya, Jai Mata Market, Tri Nagar, New Delhi- 110035.

Sub: - Inspection report in r/o Nigam Pratibha Vidyalaya located at Jai Mata Market, Tri Nagar, New Delhi- 110035.

Sir,

This is in reference to your letter no. Nil dated 22/07/2024 received via outdoor diary no. 4664 dated 29/07/2024 on the subject cited above. In this connection, it is to inform you that the above said school building was re-inspected by the officer concerned of this department on 12/08/2024 in the presence of Smt. Renu Gupta (Principal) to verify the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/School/2016/2501 dated 21/10/2016.

The status of shortcoming is as under:-

	The status of shortcoming is as under:-	Status
Sr. No	Shortcomings	Provided but not found
1.	Terrace Fire pump of 450 lpm with 40 m head is not provided.	in auto mode
2.	Terrace tank of 10000 ltrs not provided.	Provided
3.	Hose reels at each floor not provided.	Provided but found attached with domestic water tanks
1	Exit signages not provided.	Rectified
4. 5.	Five number more ABC Type fire extinguishers of 5 kg capacity should be provided.	Rectified
5.	Two staircase of 1.33 m width are provided against required two staircases of 1.50 m each.	Not Rectified

In addition to the above mentioned shortcoming it is to inform you that electrical panel and electric meter installed under the staircase have to be removed to a safer place or been segregated by fire check door.

In view of the above shortcomings, the request for issuance of Fire Safety Certificate can't be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings

under intimation to this department for further necessary action in this regard.

Yours faithfull

Ph. 011-23414000

Copy to:-

The Director, Directorate of Education, Old Secretariat, Delhi.