

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Institutional/2024/SZ/458
To

Dated: 19/08/2024

The Executive Engineer (Bldg) HQ
9th floor, Municipal Corporation of Delhi,
Civic Center, Minto Road,
New Delhi 110002

Sub: Regarding issuance of Fire Safety Certificate in r/o Nursing Home located at Plot No-
J-4, Green Park, Extension, New Delhi.

Sir,

This has reference with letter no nil dated 05/07/2024, received through outdoor diary no 3877 dated 05/07/2024 on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 09.08.2024 in the presence of Mr. Avinash to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check door not provided in lift lobby as per sanction building plans.
2. Sealing of shafts not done.
3. Smoke management system not provided in the building.
4. First aid hose reel provided but found not functional.
5. Automatic sprinkler heads covered with fall sealing.
6. Fire fighting pumps are not on auto mode.
7. Exit signage not provided at some places.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:

1. Nursing Home located at Plot No- J-4, Green Park, Extension, New Delhi -16