

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2024/SZ/ 333

Dated: 14/08/2024

To,

The Joint C.P. (Lic.),
1st floor, Police Station,
Defence Colony, New Delhi.

Sub: - Regarding renewal of FSC from fire safety point of view in r/o M/s. Pizza Hut (A unit of Devyani international Pvt. Ltd.), running at GF at 14/4, Prem Nagar, Janakpuri, New Delhi-110058.

Sir,

Please refer to online application ID 2024071511007 dated 15.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the eating house building on dated 09.08.2024 in the presence of Sh. Ramesh, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the eating house running at ground floor only of a building comprised of ground plus two upper floors, and have following shortcomings were observed: -

1. Hose reels/hydrant system found provided but not functional.
2. Terrace pump of 450 LPM found provided but not functional.
3. Overhead water storage tank capacity of 20,000 ltrs. provided but found empty.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The owner/occupier, M/s. Pizza Hut (A unit of Devyani international Pvt. Ltd.), running at GF at 14/4, Prem Nagar, Janakpuri, New Delhi-110058.