



Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/BP/2024/ 448

Dated: 14/08/2024

To,

The Executive Engineer -I (Bldg.)HQ,
Municipal Corporation of Delhi,
9th Floor, Civic Centre, Minto Road,
New Delhi – 110002.

Sub: Online building plan in r/o Plot No. 8, Block – C, Rewari Line Industrial Area, Phase-II, Mayapuri, New Delhi - 110064.

Sir,

Please refer your Request ID No. 10119165 dated 07-08-2024 on the subject cited above. In this connection this is to inform you that the online building plans have been scrutinized by this department from fire and life safety point of view and observed following shortcomings:

1. Width of staircases is not marked on the plans.
2. Compartmentation of floors is not proposed.
3. Fire Pump Room is not proposed.
4. Two different plans of ground floor have been submitted.

Therefore, plans are rejected.

Yours faithfully


(ATUL GARG)
DIRECTOR

Ph. 011-23414000

