

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

c/78

No. F6/DFS/MS/School/WZ/2024/ 541

dated: 20/08/2024

To,  
The Principal,  
M/s. Presidium Punjabi Bagh (Shri Narender Charitable Trust),  
11/77, West Punjabi Bagh, New Delhi-110026.

**Sub: - Issuance of Fire Safety Certificate in respect of Presidium Punjabi Bagh (Shri Narender Charitable Trust), located at 11/77, West Punjabi Bagh, New Delhi-110026.**

Sir,

Refer to your Email dated 04/07/2024, on the subject cited above. In this connection, it is to inform you that the premises was re- inspected by the officer concerned of this department on 02/08/2024 in the presence of Smt. Ravneet (Admin Incharge) to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/School/WZ/2024/318 dated: 12/06/2024.

The status of Shortcomings are as under:-

S. no.	Shortcomings	Status
1.	Width of the staircase is provided 1.52m, 1.25m & 1.20 to 1.5m against requirement of 1.5mx2nos.	Not Rectified
2.	Fire Check door found removed at some places	Not Rectified
3.	First Aid Hose reels & Internal Hydrant are provided but not functional	Not Rectified
4.	Automatic sprinkler system is provided in basement but found not functional.	Not Rectified
5.	Terrace fire pump capacity of 900 lpm is provided but not functional.	Not Rectified (450lpm provided against requirement of 900lpm)
6.	Overhead water storage tank capacity of 15,000ltr is found empty.	Not Rectified (10,000ltrs provided against requirement of 15,000ltrs)
7.	Exit signage's found removed at some palaces.	Rectified

In view of above shortcomings the application for issuance of fire safety certificate is rejected. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire safety arrangements.

Yours faithfully,

(Atul Garg)  
Director

Copy To: -

1. The Director, Directorate of Education, Old secretariat, Delhi - 110054.

19/8/2024