

C-3



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/547
To

Dated: 20/08/2024

The Principal,
Sahoday Junior School,
Aya Nagar, New Delhi 110047

Sub: Regarding issuance of FSC in r/o M/s Sahoday Junior School, at Aya Nagar, New Delhi 110047.

Sir,

This has reference to your letter no. nil dated 25/06/2024, received through outdoor diary no 3648 dated 01/07/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.08.2024 in the presence of Mr. Pintu to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire tender not accessible, due to the road width is less than 6 mtr.
2. There are two staircase having width of 1.47m & 1.20 mtr (iron) against the required two staircase having width of 1.50 mtr each.
3. Exit Signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.