



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

d.o.6  
7/5  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 539

Dated: 20/08/2024

To,

The Principal,  
Sanjay Memorial Public School  
East Vinod Nagar, Delhi – 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Sanjay Memorial Public School located at East Vinod Nagar, Delhi – 110092.**

Sir,

This has a reference to your Email dated 22/07/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 06/08/2024 in the presence of Mrs. Sonia Chauhan (Principal) and observed that building comprised of Basement + Ground + Three Upper Floors (School is running on G + 2 upper floor only).

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel found removed.
2. Fire pump of 220 LPM found removed.
3. Overhead tank of capacity 2500 liters found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Your faithfully,

  
(ATUL GARG)  
DIRECTOR

O/C (u) DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, MCD, 419, Udyog Sadan, Patparganj, Industrial Area, Delhi - 110092.
2. The Principal, Sanjay Memorial Public School located at East Vinod Nagar, Delhi - 110092