

c/35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 542

Dated: 20/08/2024

To,

The Principal,
Sarvodaya Kanya Vidyalaya No.-3,
Tilak Nagar, New Delhi-110018

Sub: - Regarding issuance/renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya No.-3, Tilak Nagar, New Delhi-110018.

Sir,

This has reference to your Letter No. SKV/No.3/T.N./2024/86 dated 09.07.2024, on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been inspected by the officer concerned of this department on 07.08.2024 to see the compliance of the requisite fire safety measures. Smt. Annu Sehgal was present at the time of inspection.

During the course of inspection, it was observed that school building comprised of three blocks namely Main Block, Primary Block & New Block. Main Block & New Block is having ground plus three upper floors and Primary block is having ground floor plus one upper floor. This department was issued FSC vide letter No. F.6/DFS/MS/School/2021/SZ/425 dated 02.07.2021 (for New block only). Earlier, No FSC issued for Main block and Primary block and issued shortcomings vide letter No. F.6/DFS/MS/School/2018/SZ/2156 dated 18.05.2018. Therefore, following shortcoming were observed:-

1. Hose reel system is provided but not functional at Main block and New block.
2. Fire pump having capacity 450 LPM (02 no.'s) are provided but not functional at Main block and 450 LPM pump found not functional in auto mode at New block.
3. Exit signs are not provided.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Executive Engineer (E), Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi- 110002

: - for necessary action please.