



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/BP/2024 / 453

Dated: 16/08/2024

To,

The Chief Architect
DMRC, Metro Bhawan
Barakhamba Lane Connaught place
New Delhi-110001.

**Sub: Examination of building plans from fire & life safety point of view in r/o
Extension of Workshop and Pit Wheel Lathe at Shastri Park Depot, Delhi.**

Sir,

Please refer your online building plans ID No. DMRC/Fire/161/2024/07/376 dated 22/07/2024 on the subject cited above. In this connection, this is to inform you that the referred building plans in r/o Extension of Workshop and Pit Wheel Lathe at Shastri Park Depot, Delhi have been scrutinized by this department from fire and life safety point of view and following shortcomings are observed: -

1. Six mtr. wide approach road is not clearly marked on building plans as per clause 8.2 of UBBL-2016.
2. Exit doors are not properly marked on building plans.

In view of the above, the case is rejected.

Yours faithfully,

(Atul Garg)
DIRECTOR

011 - 23414000

BP e 10