



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2024/WZ/ 459

Dated: 19/08/2024

To,

Sh. Ajay Kishor,
Re Sustainability IWM Solutions Limited,
Sector-5, DSIIDC Bawana, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Re Sustainability IWM Solutions Limited, TSDF for Hazardous Waste at Sector-5, DSIIDC Bawana, Delhi-110039.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 4686 dated 30/07/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 12.08.2024 in presence of Sh. Ajay Kishor to see the compliance of shortcomings issued vide letter number F6/DFS/MS/2024/WZ/69 dated 11/01/2024.

During the course of inspection it was observed that the building comprised of Ground Floors and Ground plus first floor. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. Smoke/ Heat detectors not provided at some locations.
2. P.A. System found provided but not functional.
3. Yard hydrants found provided but not functional.
4. Pumping system is not on auto mode.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

[Handwritten signature]