



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2024/WZ/ 540

Dated: 20/08/2024

To,

The Principal,
Vishal Bharti Sr. Sec. School,
P.S Block, Zone H 4 & 5,
Pitampura, Delhi-110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Vishal Bharti Sr. Sec. School, located at P.S Block, Zone H 4 & 5, Pitampura, Delhi- 110034.

Sir,

This has reference to your e mail id dated 29/07/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 09.08.2024 to see the compliance of the requisite fire safety measures. Sh. Ajit Singh (Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. First aid hose reels found damaged.
2. P.A system found provided but not functional.
3. Internal hydrants and yard hydrant found provided but not functional.
4. Terrace level pump found provided but not functional.
5. Exit signage's found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.