

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/FH/2024/SZ/ 302  
To

Dated: - 03/06/2024

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor PS Defence,  
New Delhi 110049.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Ashoka Avenue-I, Farm House, Asola Fatehpur Beri, New Delhi

Sir,

This has reference to with letter **MHA Portal ID 2024031102836** dated **14/05/2024** the subject cited above. In this connection, it is to inform you that the ~~above mentioned premise was visited by the officer concerned of this department on 29.05.2024~~ in the presence of Mr. Naeem to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. First aid hose reel provided but found nonfunctional.
2. MOEFA found non functional.
3. ~~Internal hydrant system provided but found nonfunctional.~~
4. Terrace level fire fighting pumps provided but found nonfunctional.
5. Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE