

C-70



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2024/SZ/508

Dated: 21 / 08 / 2024

To
The Joint Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Delhi Aerocity Inn Guest House Situated- L-22/379, NH-8, Mahipalpur Extn., New Delhi 110037.

Sir,

This has reference to with **MHA Portal ID 2024061509451 Dated 29/07/2024** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 16.08.2024 in the presence of Mr. Raj Kumar (Manger) and observed that building comprised of Basement, Ground + 04 upper floors and following shortcomings were observed during inspection :

1. Restaurant at Ground floor & the occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

