

c/42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ GH/504

DATED: 21/08/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/s East Inn Guest House Located at
11/22 East Patel Nagar New Delhi.**

Sir,

Please refer to online application No. 2024071110857, dated 24/07/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 13/08/2024 in the presence of Dr. Rajat Shodi (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Hose reel hoses found nonfunctional.
2. PA system found nonfunctional.
3. Basement could not check as the basement was closed.
4. Terrace pump found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,


(Atul Garg)
Director,
Delhi Fire Service
O/c

Copy to:-

The Manager, M/s East Inn Guest House Located at 11/22 East Patel Nagar New Delhi.