

176

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ G14/499

Dated:- 20/08/2024

To,

The Addl. Commissioner of Police (Lic.),  
Licensing Unit, Defense Colony Police Station, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Hotel Magic Tree located at 1826-1827, Laxmi Narayan Street Chuna, Mandi, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2024041805519 dated 22/07/24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned of this department on 06/08/2024 in the presence of Manager and following shortcomings were observed: -

1. CO detectors found partially nonfunctional.
2. Office at stilt floor is not allowed, it is allowed for parking only as per building bye law .

In view of above, the case is rejected. Further, occupancy of the building/ guest house without valid FSC (Fire Safety Certificate) shall be at the risk and liability of owner/occupier. Accordingly, the licensing authority may take action as deemed fit at their end.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Manager, M/S Hotel Magic Tree, 1826-1827, Laxmi Narayan Street, Chuna Mandi, Pahar Ganj, New Delhi.