



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

C. 22



Dated: 16 / 08/2024

No. F6/DFS/MS/2024/School/ 529

To,  
The Headmistress,  
Ideal Public School at Gali No-2,  
B-Block, Swaroop Vihar, Delhi-34.

Sub:- Regarding renewal of fire safety certificate in r/o Ideal Public School located at Gali No-2,  
B-Block, Swaroop Vihar, Delhi-110034.

Sir,  
Please refer to your letter no-IPS/2024/81/29 dated 29.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03.08.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & first floor only. At the time of inspection Sh. Urmila Rani (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but found not function and damaged condition.
2. Terrace level fire pump capacity of 220lpm is provided but not functional & damaged condition.
3. Terrace level fire water tank of capacity 2500ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.