

c-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2024/ 521

Dated: 16/08 /2024

To

Mrs. Vandana Gupta (In charge),  
Jain Samnopasak Senior Secondary School,  
Rui Mandi, Sadar Bazar, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Jain Samnopasak Senior Secondary School, Rui Mandi, Sadar Bazar, Delhi - 110006.**

Sir,

This has reference to your letter no. 2024-25/111 dated 09.07.2024 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by the officer concerned from this department on 02.08.2024 in the presence of Mrs. Vandana Gupta (In charge) and observed that the building is comprised of ground + 02 upper floors. During the inspection, following shortcomings were observed:-

1. There are one staircase having width of 1.50 mtr. from ground to 1<sup>st</sup> floor & second staircase having width of 1.05 mtr. for ground to terrace floor against the requirement of one staircase having width of 1.50 mtr. from ground to terrace floor, not provided.
2. First aid hose reels not provided.
3. One terrace fire pump capacity of 450 LPM + 40 mtrs. head not provided.
4. Over head water storage tank of 10,000 ltrs. capacity is required exclusively for fire fighting.
5. Exit signages are not provided.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
16/08/24

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.