



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8
आज़ादी का
अमृत महोत्सव

C-2

No.F6/DFS/MS/School/SZ/2024/535

Dated: 16/08/2024

To

The Principal,
M/s Kamla Devi Public School,
I-2, 555/9, Sangam Vihar, New Delhi-80.

Sub:- Regarding issuance of Fire Safety Certificate in respect of M/s Kamla Devi Public School located at I-2, 555/9, Sangam Vihar, New Delhi-80.

Sir,

With reference to letter bearing outdoor diary no. 1907 dated 21.05.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.08.2024 in the presence of Mr. Anand Kumar (Manager) and it was observed that the building is comprised of Ground floor only. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)

Director

Delhi Fire Service

07/08/24

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.