



0-18

7
आजादी
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2024/ 523

Dated: 16 / 08 /2024

To

The Principal/Incharge,
Nigam Prathibha Vidyalaya,
Transit Camp, Raghur Nagar,
New Delhi-110027.

Sub: - Inspection report in respect of Nigam Prathibha Vidyalaya located at Transit Camp, Raghur Nagar, New Delhi-110027.

Sir,

Please refer to your letter No. Nil received through Outdoor Diary No. 3964 dated - 09/07/2024, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 30/07/2024 in presence of Sh. Gobind Singh (Incharge) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is comprised of Ground + Two Upper Floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, etc provided. However, the following Shortcomings were observed.

1. First Aid Hose Reel is provided but not functional.
2. Main fire pump of capacity 450 lpm is not provided.
3. Over head water Storage Tank capacity of 10,000 ltrs is not provided.

In view of above Shortcomings the application for issuance of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,


(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

ole
13/8/2024