

## GOVERNMENT OF NATIONA CAPITAL TERRITOTY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/478

Dated: 12./18.../2024

The Addl. Commissioner of Police, Lic/Branch, 1st Floor, P.S Defence Colony, New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Pamposh Guest House, M-83, M- Block Market, Greater Kailash - II, New Delhi 110048.

Sir,

This has reference with MHA Portal 2024071410996 dated 14.07.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.08.2024 in the presence of Mr. Vishal Sokhal to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016
- 2. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE