

C/69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/EH/2024/SZ/ 346

Dated: 21/08/2024

To,

The Joint C.P. (Lic.),
1st floor, Police Station,
Defence Colony, New Delhi..

Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Pizza Hut (a unit of Devyani International Ltd.), GF,- 1A, GF-2A, Satyam Cinema Complex, Janakpuri, New Delhi-110058.

Sir,

Please refer to online application Id 2024073111955 received dated 31.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the eating house building on dated 19.08.2024 in the presence of store manager, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the eating house running at ground and floor only in a building comprised of basement, ground plus four upper floors, and have following shortcomings were observed: -

1. Second exit found lock and blocked by sitting arrangement.
2. Hose reels/hydrant system found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, eating house/restaurant management may be requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. The Owner/occupier, Pizza Hut (a unit of Devyani International Ltd.), GF,- 1A, GF-2A, Satyam Cinema Complex, Janak Purl, New Delhi-110058
2. Executive Engineer (Bldg.), MCD, 9th floor, Civic Centre, New Delhi- 110002.

: - for information please.