

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/ 519

Dated: 16./08./2024

To

Mr. Sarbani Sengupta (Principal)
M/s Raisina Bengali School,
Chittaranjan Park, New Delhi 110019.

Sub: Regarding issuance of FSC in r/o M/s Raisina Bengali School, Chittaranjan Park, New Delhi 110019.

Sir,

This has reference to your letter no. RBS/CR/2024/404 dated 05/07/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.08.2024 in the presence of Mr. Sarbani Sengupta (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are three staircase having width of 1.70m, 0.67 m & 0.70m against the required two staircase having width of 1.50 mtr each.
2. First aid hose reel provided but nonfunctional.
3. Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
4. Exit Signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.