



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8
आजादी का
अमृत महोत्सव

Dated: 16/08/2024

No.F6/DFS/MS/School/SZ/2024/ 533

To

The Principal,
R. K. Public School,
F-17/18, Khanpur Extension,
(Behind Ambedkar Nagar Bus Depot), New Delhi-80.

Sub:- Regarding issuance of Fire Safety Certificate in r/o M/s R. K. Public School located at F-17/18, Khanpur Extension, (Behind Ambedkar Nagar Bus Depot), New Delhi-80..

Sir,

With reference to letter bearing outdoor diary no. 2300 dated 31.05.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.08.2024 in the presence of Mrs. Kavita Yadav (Principal) and it was observed that the building is comprised of Ground + 04 upper floors. During the inspection following shortcomings were observed:-

1. 2 nos. of staircases having width 1.50 meters each not provided.
2. 10 nos. of fire extinguishers not provided.
3. First aid hose reels not provided at each floor.
4. Fire pump of 450 LPM with head 40 m not provided.
5. Terrace water tank of 10,000 liters not provided (exclusively for firefighting).
6. Exit signages not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

07/8/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Executive Engineer (Building), MCD, Jal Vihar, Lajpat Nagar, New Delhi-24:- To verify the height of the building under intimation to this department.