



No. F6/DFS/MS/School/NDZ/2024/ 527

Dated: 16/08/2024

To,

The Principal,  
Shiv Public School,  
1/11242, Subhash Park,  
Near Kirti Mandir,  
Shahdara, Delhi - 110032.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Shiv Public School located at 1/11242, Subhash Park, Near Kirti Mandir, Shahdara, Delhi - 110032.**

Sir,

This has a reference to your outdoor no. 4530 dated 24/07/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 06/08/2024 in the presence of Mrs. Anshu Aggarwal (Principal), and observed that building comprised of Ground plus two upper floors (School is running ground plus one upper floor).

**Following shortcomings were observed during time of inspection:**

1. One staircases of width 1.0 meter is provided only. Other staircase of 1.2 meters width found removed.
2. Fire Extinguishers found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Your faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to:-**

1. The Director of Education, MCD, 419, Udyog Sadan, Patparganj, Industrial Area, Delhi - 110092.
2. The Principal, Shiv Public School, 1/11242, Subhash Park, Near Kirti Mandir, Shahdara, Delhi - 110032.