



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/8
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2024/ 534

Dated: 16/08/2024

To

The Principal,
M/s S.V.C.S. Public School,
K-1st/18, Plot no. 236, Sangam Vihar,
New Delhi-80.

Sub:- Regarding issuance of Fire Safety Certificate in respect of M/s S.V.C.S. Public School located at K-1st/18, Plot no. 236, Sangam Vihar, New Delhi-80.

Sir,

With reference to your letter no. SVCS/27 dated 29.07.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 03.08.2024 in the presence of Mr. Malik Arjun (Manager) and it was observed that the building is comprised of Ground + 1 upper floors. During the inspection following shortcomings were observed:-

1. School is not accessible to fire engine due to encroachment.
2. An additional staircase is required having width not less than 0.75 meters.
3. Exit sinages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.