

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F6/DFS/MS/EH/2024/SZ/ 4(1)

Dated: 20 08 2024

To,

Executive Engineer (E), DTTDC Ltd., Srinivaspuri, Lajpat Nagar Near Cambridge School, Ring Road, New Delhi-110065.

Sub: -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Food Court, Dilli Haat, Janakpuri, New Delhi-110071.

Sir,

Please refer to your letter No. 23(31)/DTTDC/Engg./EE(E)/2024-25/176 dated 06.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the eating house building on dated 06.08.2024 in the presence of Ganga Sahay Meena (AE), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the eating house running at ground and first floor only in a building comprised of basement, ground and first floor only, and have following shortcomings: -

Staircases and ramp found blocked.

2. Hose reels/hydrant system found provided but not functional.

- 3. Automatic fire detection and alarming system found provided but not functional.
- 4. MOEFA found provided but not functional.
- 5. PA System found provided but not functional.
- 6. Pumps are found not functional.
- 7. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

Delhi Fire Service

Copy to:-

1. The Joint C.P. (Lic.), 1st floor, Police Station, Defence Colony, New Delhi.

: - for necessary action please.

2. Executive Engineer (Bldg.), MCD, 9th floor, Civic Centre, New Delhi- 110002.

: - for information please.