

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 19/08/2024

No. F.6/DFS/MS/GH/2024/SZ/496
To

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Hotel Ambrosia, A-217, Kh. No 416, Road
no 6, VPO Mahipalpur New Delhi-110037

Sir,

This is in reference with **MHA Portal ID 2024062509938 dated 19-07-2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 16.08.2024 in the presence of Mr. Veeru Singh (Manager). During the inspection, it was observed that Basement, Ground plus three upper floors. The shortcomings observed are as below:

- 1 Fire check doors not provided at ground floor as per clause 7.31 of UBBL 2016.
- 2 Smoke management system not provided as per clause 7.31 of UBBL 2016.
- 3 First aid hose reel provided but found not working.
- 4 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 5 Automatic sprinkler system provided but found non-functional.
- 6 Terrace level fire fighting pumps capacity 900 LPM provided but found not working.
- 7 Exit signage's found removed at some places.
- 8 The Kitchen /Staff room at terrace level is not allowed and Occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE