

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/500

Dated: 20/08/2024

To

The Addl. Commissioner of Police (Lic.),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Issuance of FSC in r/o M/s Hotel Paradise International at Plot No A-272, NH-8,
Mahipalpur New Delhi 110037.

Sir,

This is in reference with your request through **MHA Portal ID 2024072011325**
Dated 20/07/2024 on the subject cited above. In this connection, it is to inform you
that the premise have been inspected by officer concerned of this department on
16/08/2024 in the presence of Mr. Veer Singh (Manger) and observed that the Guest
House is running in Basement (Parking) Ground plus Three Upper Floors (01Staff Room
at Terrace). During the course of inspection, the following shortcoming observed were
noticed:-

1. The Occupancy above 3rd Floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate
is rejected. The occupancy of the building/premises in absence of requisite fire safety
arrangements shall be at the risk and liability of the owner/occupier. The Licensing
authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE