

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/512
To

Dated: 21/08/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Hotel Star Inn, A-206, Street No 9, Road No 4, Mahipalpur, New Delhi- 110037.

Sir,

This is in reference with **MHA Portal ID 2024072611637** dated **26/07/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 16/08/2024 in the presence of Mr. Ashish (Manager) of the Guest House. During the inspection, it was observed that the guest house running at Lower ground, Ground + 03 Upper Floor only. The shortcomings observed are as below;

1. First aid hose reel provided but found not working.
2. MOEFA not working.
3. Terrace level fire fighting pumps provided but found not working.
4. Overhead fire fighting water tank found domestic connection.
5. Exit signage found removed at some places.
6. Kitchen above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

[Handwritten signature]