

c/83

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ Gh | 505

Dated: 21/08/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o Hotel Elegant International located at Ground, 1st & 2nd floor & 3rd floor, 6/28, WEA Karol Bagh, New Delhi - 110005


Sir,

Please refer to online application No. 2024053108564, dated 31/05/2024 on the subject mentioned above. In this connection it is to inform you that the premises was visited by the officer concerned from this department on 16/08/2024 to see the compliance of Gazette Notification No F.5(189)/AD/LB/2016/4053-67 dated 27/05/2019 in the presence of Sh. Balem Singh (Manager) and observed that:-

1. Fire check door are still not provided.

In view of the above the Fire Safety Certificate issued vide letter no No.F6/DFS/MS/SZ/2021/438 dated 29/09/2021 is already stand cancelled. The applicant is directed to comply the above shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to: - The Manager, M/s Hotel Elegant International located at Ground, 1st & 2nd floor & 3rd floor, 6/28, WEA Karol Bagh, New Delhi - 110005.