

C-115

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/509

Dated: 21/08/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Punjab Hotel situated at 669,
Church Mission Road, Delhi.

Sir,

This has reference to online application I.D. no. 2024073111972 dated 02.08.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 16.08.2024 in the presence of Mr. Rajinder (Manager) and it was observed that building is comprised of Basement + Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors which are required as per gazette notification dated 27.05.2019, not provided.
2. Fire extinguishers provided but non functional.
3. CO detectors with panel and alarm system which are required as per gazette notification dated 27.05.2019, not provided.
4. PA system provided but not functional.
5. Fire pump not in auto start mode.
6. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Anil Garg)
Director
Delhi Fire Service
Tel: 011-23414000
20/08/24

Copy to:-

The Licensee,
M/s Punjab Hotel situated at 669, Church Mission Road, Delhi - 110006.