

C58



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/EH/2024/ 335

Dated 14/08/2024

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: -Regarding renewal of fire safety certificate in r/o M/s Sazy Bear (A Unit of Mad Food And Beverages LLP) located at Plot No-2628, 2nd & 3rd Floor, Hudson Line, GTB Nagar, Delhi-110009.

Sir,

This has reference to your online MHA Portal I'd No. 2024072611636 Dated: 26.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 07.08.2024 in the presence of Sh. Deepak to verify the fire safety arrangements as stipulated in NBC Part 4. During the course of inspection it was observed that the building premise is comprised of basement, ground & 03 upper floors (but restaurant running at second & third floor only). Your request for FSC is rejected under Rule 36 (3) due to following shortcomings.

1. Fire check door found removed in staircase at second floor.
2. Smoke detector, alternate source of power & hooter found removed.
3. Diesel engine capacity of 2280lpm found removed at site and auto system not functional.
4. Under ground fire water tank capacity of 1, 00,000ltrs found empty.
5. Standby power supply found removed.

In view of the above shortcoming, the application for renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

10/8