

C-57

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 5/5

Dated: 22/08/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s S. K. Palace Guest House situated at 3854-3858, Khirki Taffazzul Hussain, Kalan Mahal, Darya Ganj, Delhi -06.

Sir,

This has reference to online application I.D. no. 2024062109744 dated 30.07.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 16.08.2024 in the presence of Mr. Atiqr Rehman (Owner) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers not adequately provided.
2. First aid hose reels not provided.
3. CO detectors with panel and alarm system which are required as per gazette notification dated 27.05.2019, not provided.
4. Fire pump not in auto start mode.
5. Exit signages are not provided.
6. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
ok  
2/08/24  
19/8

**Copy to:-**

The Licensee,

M/s S. K. Palace Guest House at 3854-3858, Khirki Taffazzul Hussain, Kalan Mahal, Darya Ganj,  
Delhi -06.