

c-75

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2024/ 511

Dated: 21/08/2024

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Tamanna Guest House** situated at **2294, Gali Qasim Jan, Ballimaran, Delhi -06.**

Sir,

This has reference to online application I.D. No. 2024072911745 dated 29.07.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 16.08.2024 in the presence of Mohd. Suhaib Ahmed (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors which are required as per gazette notification dated 27.05.2019, not provided.
2. Fire extinguishers provided but non functional.
3. CO detectors with panel and alarm system provided but not functional.
4. Fire pump not in auto start mode.
5. Exit signages are not adequately provided.
6. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,



(Atul Garg)  
Director

Delhi Fire Service

Tel: 011-23414000

SO 19/8  
19/8

**Copy to:-**

The Licensee,  
M/s Tamanna Guest House at 2294, Gali Qasim Jan, Ballimaran, Delhi - 110006.