

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/ 474  
To

Dated: 27/08/2024

The Joint Commissioner of Police, Lic/Branch,  
1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Bouncing Pouncing located at Ground floor of Okhla NSIC Metro Station of Line 8 (Janak Puri West to Kalindi Kunj Section) New Delhi

Sir,

This has reference to your **MHA Portal ID 2024080112025 dated 01/08/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19/08/2024 in the presence of Mr. Ritesh Jain to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are three exit doors available in the game zone. Out of there three, one door having width of 2 mtr is open & two doors found closed.
2. Exit signage's not provided at some places.
3. There is no eating house running in the premise. The Game zone is needs to be referred through concerned licensing authority.
4. Inflammable material (Plastic & PVC Sheets for decorative material) used for toys & wall paneling/ ceiling level, which is not acceptable as per clause 7.31 of UBBL-2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE