

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/352

Dated 27 / 08 / 2024

To

The Addl. Commissioner of Police,
Lic Branch, 1st Floor PS Defence colony,
New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Goverdhan Motel & Restaurant at Plot No 84, GF & FF, Sri Aurobindo Marg, Adhchini, New Delhi 110017.

Sir,

This has reference with **MHA Portal ID 2023080714179 dated 27/07/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20/08/2024 in the presence of Mr. Varun Gupta to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There are two exits having width of 1.50 mtr & 1.40 mtr against the required width of 1.50 mtr each respectively.
2. First Aid Hose Reel provided but found nonfunctional.
3. The MOEFA system provided but found nonfunctional.
4. The Internal Hydrant provided but found nonfunctional.
5. Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
6. Overhead tank capacity 5,000 ltrs provided against the required capacity 20,000 ltrs.
7. The Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE