

c/124

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI- 110001**

No. F6/DFS/MS/GH/2024/SZ/ 519

Dated: 23/08/2024

To,

The Joint C.P. (Lic.),  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o M/s. Vicky Guest House located at C-222, Mayapuri Industrial Area, Ph.- II, New Delhi- 110064.**

Sir,

Please refer to online application ID 2024071911237 dated 24.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the guest house building on dated 13.08.2024 in the presence of Caretaker, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the guest house running at first and second floor only in a building comprised of basement, ground plus two upper floors, and have following shortcomings: -

1. Hose reels found provided but not functional.
2. MOEFA found provided but not functional
3. Terrace fire pump of 450 LPM is provided but found not functional.
4. Exit signage's are found removed.
5. Basement is found used as shops.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running guest house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

alc

Copy to:-

1. The Owner/Occupier, M/s. Vicky guest house at C-222, Mayapuri Industrial Area, Phase- II, New Delhi- 110064.
2. Executive Engineer (Bldg.), MCD, 9<sup>th</sup> floor, Civic Centre, Minto Road, New Delhi- 02.  
: - for informed n.a. in r/o use of basement.