

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/351
To

Dated 27/08/2024

The Joint commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o KFC Restaurant, Shop No C-5,
Ground floor, Main Market, Malviya Nagar, New Delhi-110017

Sir,

This has reference to with **MHA Portal ID 2024080912450 dated 09/08/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.08.2024 in the presence of Ms. Priyanka (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, ground and 03 upper floors but the restaurant is running at ground floor only. During inspection, following points were observed:

- 1 The First aid hose reel hose provided but found not working.
- 2 Internal hydrant provided but found not working.
- 3 Terrace level fire fighting pump provided but found not working.
- 4 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE