

c/16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 479

Dated:-13/08/2024

To,
The Addl. Commissioner of Police (Lic),
First Floor, P.S. Defence Colony New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Rajput Guest House, 194, Ghee Mandi, Pahar Ganj, New Delhi.

Sir,
This has reference to on line ID No. 2024072011322 dated 20/07/2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 06/08/2024 in the presence of Mr. Ram Sahay and following shortcomings were observed: -

1. First aid hose reel found non functional.
2. Pumps found non functional.
3. Over head tank found empty.

Hence, the case is rejected and FSC issued vide letter no. No. F6/DFS/MS/GH/NDZ/2021/488 dated 01/11/2021 shall stand null & void and cannot be renewed till the compliance of above shortcomings. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The licensing authority may take suitable action as deemed fit.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

1. The Commissioner North, MCD, Civic Centre, New Delhi.
2. The Manager, Rajput Guest House, 194, Ghee Mandi, Pahar Ganj, New Delhi.