



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/554

Dated: 27/08/2024

To

The Manager  
Ravindra Memorial Public School  
at 7360/10-11, Prem Nagar,  
Shakti Nagar, Delhi-110007.

**Sub:** - Regarding issuance of fire safety certificate in r/o Ravindra Memorial Public School located at 7360/10-11, Prem Nagar, Shakti Nagar, Delhi-110007.

Sir,

Please refer to your letter No. RMPS/24-25/17 Dated 18.06.2024 received in this department vide outdoor dairy no.3042 dated: 18.06.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 08.07.2024 to check the existing fire safety measures. During inspection it has been observed that the school is running in 02 blocks interconnected to each other comprised of ground & 03 upper floors only. At the time of inspection Sh. Rajiv Malhotra (Owner) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. The main gate width of 2.60m against the requirement of 4.50m.
2. Staircase at second floor of the school building is through classroom (occupied area), which is not permitted.
3. Hose reel hose is not provided.
4. Terrace level fire pump capacity of 450lpm with auto starting of pump is not provided.
5. Terrace level fire water tank capacity of 10,000ltr is not provided.
6. Exit signage and floor signage is not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director  
Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

