

e-106



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hotel/2024/SZ/GH/465

Dated 06/08/2024

To

The Joint Commissioner of Police
(Lic. Branch) 1st Floor, P.S. Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Zone Connect Saket** located at DLF South Court Mall, A-1, District Centre, Saket, Delhi- 110017

Sir,

This has reference with **MHA Portal ID 2024070110235 dated 08/07/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.08.2024 in the presence of Mr. Ramesh Gupta to verify the fire safety measures installed in the building and during inspection, following points were observed:

- 1 Electrical installation / meter found installed in the escape routes under the staircases, which is not acceptable.
- 2 The Exit signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE