

c/30

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ Sch | 556

DATED: 27/08/2024

To,

The Principal,
DAV Public School,
West Patel Nagar
New Delhi-110008.

Subject: - Renewal of Fire safety Certificate in r/o DAV Public School, Located at West Patel Nagar New Delhi-110008.

Sir,

Please refer to your Letter no DAV/PS/WPN/2024-25/77 dated 03/08/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been re-inspected by the officer concerned of this department on 13/08/2024 in presence of Sh. Vikesh Aggarwal (Teacher) from fire safety point of view.

During the course of inspection following shortcomings are observed:-

1. One staircase found locked.
2. 2nd Floor found being used for school activities without providing fire safety provisions for a building of ground plus two upper floors..
3. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation with this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

ok
27/8/24

Copy to: The Directorate of Education Old Secretariat Delhi – 110054.