




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

dot



No: F.6/DFS/MS/School/2024/WZ/ 564

Dated: 28/08/2024

To,

The Principal,
Aditya Bharti Public School,
Sec. A-5, Pocket 8,
Sunday Bazar Road,
Narela, Delhi-110040.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Aditya Bharti Public School located at Sec. A-5, Pocket 8, Sunday Bazar Road, Narela, Delhi- 110040.

Sir,

This has reference to your email id dated 25.07.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 08.08.2024 in presence of Smt. Krishna Sehrawat (Principal) to verify the fire safety arrangements provided therein.

During the course of inspection it was observed that school building is comprised of Ground and First floor. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only one staircase of width 1.50 m provided against the requirement of two staircases of width 1.50 m each.
2. Door width found 0.90 m against the required width of 1.20 m.
3. Exit signage's not provided.
4. Building plan in a scale of 1:100 not provided/ As built plan duly signed by Regt. Architect and owner are not provided .

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Anil Garg)

Director

Ph: 011-23414000

ole R

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.