

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 470

Dated: 23/08/2024

To,
The Authorized Signatory,
M/s Him Hit CGHS
Plot no-08, Sector -22, Dwarka
New Delhi-110075

Subject: Grant of Fire Safety Certificate in r/o M/s Him Hit CGHS located at plot no-08, sector -22, Dwarka New Delhi-110075.

Sir,

Please refer to your Email dated 23/07/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 12/08/2024 for the safety point of view.

During the course of inspection following shortcomings have been observed

1. The internal road found encroached.
2. The stairs are found partially blocked and locked at terrace level.
3. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire Extinguishers at some floors.
4. Terrace Pump of 450 lpm with 40m head found nonfunctional in auto mode.
5. PA system found Nonfunctional.
6. Exit signage found removed at some places.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the above said shortcomings under intimation to this department for further necessary action.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

Copy to:-

1. Joint Director, DDA(Big.), Vikas sadan, INA, New Delhi