



No. F6/DFS/MS/School/NDZ/2024/ 557

Dated: 27/08/2024

To,

The Principal,  
PM Shri Kendriya Vidyalaya,  
NFC Vigyan Vihar,  
Delhi-110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o PM Shri Kendriya Vidyalaya located at NFC Vigyan Vihar, Delhi - 110092.**

Sir,

This has a reference to your Email dated 08/08/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 12/08/2024 in the presence of Dr. Gaya Ravidas (Principal), and observed that building comprised of ground plus four upper floors only.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel provided but not functional.
2. Pumping Arrangements provided but not functional.
3. Overhead water storage tank capacity 5,000 liters is provided against requirement of 10,000 liters.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education (Land & Estate), Directorate of Education, Lucknow Road, Delhi - 110053.