

c/21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 568

Dated: 29/08/2024

To,

The Principl,  
Govt. Co-ed. Sr. Sec. School,  
Khera Dabar, New Delhi- 110073.

**Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Govt. Co-ed. Sr. Sec. School at Khera Dabar, New Delhi- 110073.**

Sir,

Please refer to your letter No. KDS/2024-25/150 dated 23.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 20.08.2024 in the presence of Mrs. Sunita (Vice Principal), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building having two blocks namely old block comprised of ground floor only and new block comprised of ground plus three upper floors. Therefore, following shortcomings were observed: -

1. Hose reels/hydrant system provided but found not functional at new block.
2. Terrace fire pump of 450 LPM provided but found not functional at new block.
3. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully,

  
(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.