

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI d23
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 567

Dated: 29/08/2024

To,

The Principal,
Guru Harkishan Public School,
Fateh Nagar, New Delhi-110018.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Guru Harkishan Public School, Fateh Nagar, New Delhi-110018.

Sir,

Please refer to your letter No. GHPS/FN/9983 dated 16.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 09.08.2024 in the presence of Rashpal Singh (Caretaker), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school having 03 blocks namely Senior block, Primary & middle block. Senior block comprised of basement (library, office music class room & other activities room), ground plus three upper floors and Primary block comprised of basement (storage), ground plus two upper floors & middle Block comprised of ground floor (Gurdwara, canteen & one office) only. Therefore, following shortcomings were observed: -

1. Classes are running in basement should be avoided and basement should be used as per BBL/UBBL.
2. Advised to submit sanction basement building plan of school.
3. Overhead water storage tank capacity of 5,000 ltrs found provided against requirement capacity of 15,000 ltrs in Senior block.
4. Pump found not functional in auto mode.
5. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.

2. The Executive Engineer, Bldg., Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi- 110002. w.r.t the use of basement.