



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SEVRVICE, NEW DELHI-110001

No. F.6/DFS/MS/Institutional/2024/SZ/482
To

Dated: 30/08/2024

The Authorized Signatory,
M/s Irene Hospital
DD-23, Kalkaji Extn,
New Delhi- 110019.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Irene Hospital at DD-23, Kalkaji Extn, New Delhi 110019.

Sir,

This has reference with letter no IRENE/DFS dated 29/07/2024, received through outdoor diary no 4994 dated 06/08/2024 on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 22.08.2024 in the presence of Mr. Birender Tiwari (Manager) to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Gate width is less than the required width.
2. Width of staircase is less than required width.
3. Fire check door not provided.
4. Width of corridor is less than required width.
5. Compartmentation not provided.
6. Smoke management system not provided at basement floor.
7. Underground water storage tank of 50,000 ltr not provided.
8. Exit signage not provided at some places.
9. Pressurization of lift shaft not provided since it is communicating in basement floor.
10. Fireman switch provided but not functional.
11. Lift signage not provided.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE