

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI HEAD QUARTERS: DELHI FIRE SEVRVICE, NEW DELHI-110001

To

Dated: 29 /08 /2024

The Executive Engineer (Bldg) HQ, Municipal Corporation of Delhi, 9th floor, Civic Center, Minto Road, New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Plot No. 53, Block-A, Okhla

This has reference with online ID 10086394 dated 21/08/2024 on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 27.08.2024 along with Mr. R.S Meena JE (Bldg) MCD & Mr. Anil Bansal AE (Bldg) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

- 1. The Staircase is not properly segregated at ground floor as per clause 7.11 (t) of UBBL 2016 & staircase is less than of 1.50 mtr at some locations. 2. Fire check door not provided.
- Smoke management system not provided.
- 4. Automatic sprinkler system provided but found non-functional.
- 5. First aid hose reel provided but found nonfunctional.
- 6. Electrical fire pumps capacity 900 LPM, Diesel Engine pumps 1620 LPM and Jockey Pump 180 LPM provided against the required Electrical Fire Pump capacity

7. Terrace level fire fighting pump capacity 450 LPM provided against the required

8. Underground tank & overhead tank found empty.

Exit signage not provided.

10. Electrical penal and generator found installed in front gate of premise, which need

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

DIRECTOR

DELHI FIRE SERVICE