

C-155

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2024/ 484

Dated: 30/08/2024

To,
The Joint Commissioner of Police (lic.),
First Floor, P.S. Defence Colony,
New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o ITPO Halls No. 7A, B, C, D, E, F, G, H, 8, 9, 10, 11, 12, & 12 A, located at Mathura Road, New Delhi.

Sir,

This has a reference to letter no. 430-35/Joint C.P./Lic. (Amst.) dated 31.07.2024, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officers concerned of this department on 21/08/24 in the presence of Sh. Amit (Manager) & Sh. V.K.Singh GM and observed the following shortcomings.

1. PA system found nonfunctional.
2. Detectors found nonfunctional at some places.
3. Hose reel not covering entire area at first floor.
4. Lifts signages are not provided.
5. Stand by power supply not provided of firefighting system.

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to ;

1. Sh. Abhishek Kumar, Manager, ITPO, Pragati Bhawan , Pragati Maidan, New Delhi.
2. Sh. V.K. Singh, GM, ITPO, Pragati Bhawan , Pragati Maidan , New Delhi.